



245 N 1st E
Rexburg, ID 83440

Lab #: 129

Project #: 25029

Project Name:

Client:

Material Description: Sand

Sample Received: March 5, 2025

Report Date March 10, 2025

Sieve Analysis

ASTM C136

SIZE	PASSING	SPECIFICATION	
		Low	High
3"	100%		
2"	100%		
1 1/2"	100%		
1"	100%		
3/4"	100%		
1/2"	100%		
3/8"	100%		
No. 4	100%		
No. 8	87%		
No. 16	65%		
No. 30	31%		
No. 50	8%		
No. 100	2%		
No. 200	1.1%		

Moisture Content As Received
ASTM D2216

2.2%

